



3348 Route 208, Campbell Hall, NY 10916
 Phone: 845-496-1600 Fax: 845-496-1398
 12960 Commerce Lake Drive, A14, Fort Myers, FL 33913
 42 Day Farm Road, West Stockbridge, MA 01266
 1813 State Route 7, Harpursville, NY 13787
 877 US-4, Schuylerville, NY 12871

Client:	Aden Aggregates	Project:	Grasso Quarry QC 2025
Item:	#2 Stone	Project Number:	250005
Source:	Grasso Quarry	Lab Number:	25-0003B
Date Sampled:	1/2/2025	Sampled By:	Client
Date Tested:	1/3/2025	Tested By:	Michael Flaherty

GRADATION (SIEVE ANALYSIS) OF SOIL OR AGGREGATE
Test Method(s): ASTM D422, C136, C117; AASHTO T88, T27, T11

Lab Number	Sample Type	Sampling Location	Specification
25-0003B	#2 Stone	Stockpile	NYSDOT 703-02 #2 Stone

Sieve Size		% Retained	% Passing	Spec. % Pass
mm	Inches			
63.0 mm	2 1/2"	0.0	100	
50.0 mm	2"	0.0	100	
37.5 mm	1 1/2"	0.0	100	100
25.0 mm	1"	1.7	98	90-100
19.0 mm	3/4"	28.9	69	
12.5 mm	1/2"	63.1	6	0-15
6.3 mm	1/4" f	4.9	1	
3.18 mm	1/8"	0.1	1	
Pan		1.3		

Comments: Test results comply with specification

Emily J. Rodriguez

Report Reviewed By:

This report shall not be reproduced, except in full, without written permission from Advance Testing Company, Inc.
 The results in this report relate only to the items inspected or tested.