



3348 Route 208, Campbell Hall, NY 10916

Phone: 845-496-1600 Fax: 845-496-1398

12960 Commerce Lake Drive, A14, Fort Myers, FL 33913

42 Day Farm Road, West Stockbridge, MA 01266

1813 State Route 7, Harpursville, NY 13787

877 US-4, Schuylerville, NY 12871

<b>Client:</b>	Aden Aggregates	<b>Project:</b>	Montgomery Yard QC 2025
<b>Item:</b>	Long Island Beach Sand	<b>Project Number:</b>	250360
<b>Source:</b>	Aden Aggregates	<b>Lab Number:</b>	25-0351
<b>Date Sampled:</b>	4/2/2025	<b>Sampled By:</b>	Client
<b>Date Tested:</b>	4/4/2025	<b>Tested By:</b>	Sean Curry

### GRADATION (SIEVE ANALYSIS) OF SOIL OR AGGREGATE

Test Method(s): ASTM D422, C136, C117; AASHTO T88, T27, T11

Lab Number	Sample Type	Sampling Location	Specification
25-0351	Long Island Beach Sand	Stockpile	Pipe Bedding Sand

Sieve Size		%	%	Spec. %
mm	Inches	Retained	Passing	Pass
6.3 mm	1/4"	0.0	100	100
4.75 mm	#4	0.0	100	
2.36 mm	#8	1.4	99	
1.18 mm	#16	7.8	91	
0.600 mm	#30	29.1	62	
0.300 mm	#50	47.2	15	0-35
0.150 mm	#100	12.9	2	0-10
0.075 mm	#200	1.0	0.6	
Pan		0.6		

Comments: **Test results comply with specification**

Minus #200 by wash-sieve method.

*Emily J. Rodriguez*

Report Reviewed By:

The simple acceptance/rejection decision rule is utilized to determine in-tolerance and out of tolerance or pass/fail conditions and no measurement of uncertainty is applied in this determination.

This report shall not be reproduced, except in full, without written permission from Advance Testing Company, Inc.

The results in this report relate only to the items inspected or tested.

PDF