



3348 Route 208, Campbell Hall, NY 10916
Phone: 845-496-1600 Fax: 845-496-1398
12960 Commerce Lake Drive, A14, Fort Myers, FL 33913
42 Day Farm Road, West Stockbridge, MA 01266
1813 State Route 7, Harpursville, NY 13787
877 US-4, Schuylerville, NY 12871

Client:	Aden Aggregates	Project:	Javeline Mine QC 2025
Item:	3/4 Stone	Project Number:	250004
Source:	Javeline Quarry	Lab Number:	25-0675
Date Sampled:	6/4/2025	Sampled By:	Client
Date Tested:	6/9/2025	Tested By:	Michael Flaherty

GRADATION (SIEVE ANALYSIS) OF SOIL OR AGGREGATE

Test Method(s): ASTM D422, C136, C117; AASHTO T88, T27, T11

Lab Number	Sample Type	Sampling Location	Specification
25-0675	3/4 Stone	Stockpile	NYS DOT #2 Stone

Sieve Size		% Retained	% Passing	Spec. % Pass
mm	Inches			
37.5 mm	1 1/2"	0.0	100	
25.0 mm	1"	52.6	47	
19.0 mm	3/4"	34.9	13	
12.5 mm	1/2"	10.8	2	
9.5 mm	3/8"	0.4	1	
4.75 mm	#4	0.2	1	
2.36 mm	#8	0.1	1	
Pan		1.0		

Comments:

Emily J. Rodriguez

Report Reviewed By:

The simple acceptance/rejection decision rule is utilized to determine in-tolerance and out of tolerance or pass/fail conditions and no measurement of uncertainty is applied in this determination.

This report shall not be reproduced, except in full, without written permission from Advance Testing Company, Inc.

The results in this report relate only to the items inspected or tested.

PDF