



3348 Route 208, Campbell Hall, NY 10916

Phone: 845-496-1600 Fax: 845-496-1398

12960 Commerce Lake Drive, A14, Fort Myers, FL 33913

42 Day Farm Road, West Stockbridge, MA 01266

1813 State Route 7, Harpursville, NY 13787

Client:	Aden Aggregates	Project:	Bloomington Quarry 2025
Material:	Concrete Sand	Project Number:	250477
Source:	Bloomington Quarry	Lab Number:	25-1283
Location:	Stockpile	Item Number:	C-33
Date Sampled:	9/19/2025	Sampled By:	Client
Date Tested:	10/8/2025	Tested By:	John Brinsfield/Michael Flaherty

Report of Lightweight Particles in Aggregate

Test Method: AASHTO T113, ASTM C123

Fine Aggregate

Type of Sample	Concrete Sand	
Nominal Maximum Size	45724	
Size Range Tested	+#50	

Mass of Sample Used, g	264.3	
Solution Used	ZnBr	
Specific Gravity of Solution	2.40	
% Lightweight Particles in Aggregate	0.00	
Percent Lightweight Chert, sp gr <2.40	0.00	
Percent Coal and Lignite	0.00	

Comments:

Emily J. Rodriguez

Report Reviewed By: _____

The simple acceptance/rejection decision rule is utilized to determine in-tolerance and out of tolerance or pass/fail conditions and no measurement of uncertainty is applied in this determination.

This report shall not be reproduced, except in full, without written permission from Advance Testing Company, Inc.

The results in this report relate only to the items inspected or tested.

PDF